

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor Richard J. Leinenkugel, Secretary

October 29, 2009

AHRENS AGRICULTURAL IND., INC. MIRACO CARTER THOMSON P.O. BOX 686 GRINNELL IA 50112

Re: Description: WATERER, ANIMAL

Manufacturer: AHRENS AGRICULTURAL IND., INC.

Product Name: MIRAFOUNT

Model Number(s): 3330, 3354, 3370, 3390, AND 3465

Product File No: 20090332

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.41 (3) (a) 1 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2015.

This alternate approval is contingent upon compliance with the following stipulation(s):

• Approval is issued for this product because the design of the product meets the intent of s. Comm 82.41 (3) (a)1, Wis. Adm. Code that requires potable water supplies protected against contamination due to backflow. The intent of the code is met since this product provides an acceptable means of backflow protection.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050031.

This approval supersedes the approval issued on March 17, 2005 under product file number 20050031.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742

Fax: 608-267-9566

E-mail: jerry.thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 09033203.DOC